



TENT AND FIRE CODE REMINDER FOR ALL PARTICIPANTS

Installation Requirements for All Tents & Membrane Structures:

- Structures must be secured to the ground using at least 24" double-headed tent stakes or larger if so required by the manufacturer.
- Structures must be strapped to stakes and/or weights with a minimum of 2" ratchet straps.
- Canopies must be properly fastened or otherwise attached to frame to prevent separation.
- Groupings or rows of consumer-grade tents (EZ-UP and similar style) with any sidewalls installed may not exceed 400-sq. ft. in aggregate size.
- Groupings or rows of consumer-grade canopies (EZ-UP and similar style) with no sidewalls installed may not exceed 700-sq. ft. in aggregate size.

Safety Requirements for All Tents & Membrane Structures:

- A minimum of two points of ingress and egress must be clearly labeled with EXIT signs.
- EXIT signs must have red lettering on a white background.
- Exits from the structure must provide a clear width of 6-ft at all times.
- A minimum of one 5lb fire extinguishers must be provided in each structure.
- Structures larger than 400 square feet, or with any dimension exceeding 75', additional extinguishers are required to ensure that no extinguisher is more than 75' away from any point in the tent.
- Extinguishers must be clearly identifiable and remain easily accessible.

Fuel storage and fueling requirements:

- A maximum of 5-gallons of fuel per kart may be stored/maintained awaiting use.
- Fuel must be stored outside ANY tent, canopy, or other structure. Fuel may be stored in trailers with proper venting.
- Refueling of Karts or other equipment must be performed at least 20-ft from ANY tent, canopy, or other structure.